

# Evaluation of the Flexibility Potential of Internal Storage Options in Thermal Power Plants by Means of Transient Simulation




[0]

# Overview

- Background and Motivation
- Modeling
- Presentation of Models
- Preliminary Results
- Upcoming Tasks

# Background and Motivation

- Energy transition in Germany: Necessity to increase the flexibility of conventional power plants
  - ▶ Increased number of load changes
  - ▶ Lower minimum load
  - ▶ Higher load gradients



- Measures to increase plant flexibility necessary → internal storages
- Dynamic simulation: Possibility of analysis of time-dependent effects of the energy transition on conventional power plants independent from real power plant operation

# Background and Motivation

- Goal: Short-term provision of power (primary control)
- Measures:
  - Usage of existing storage in water-steam cycle
    - Condensate retention
    - Deactivation of preheaters
  - Potential through extension of existing storage
    - Feedwater tank
    - Cold condensate tank
  - Outlook: Potential of combined heat and power in district heat networks
    - Heat storage
    - Power-to-heat

## Approach / Status

- Power plant modeling with regard to design data / performance data
  - ▶ Detailed modeling of water-steam cycle of reference plant: ✓
  - ▶ Detailed modeling of steam generator: ✓
  - ▶ Merging of models: *In progress*
  - ▶ Implementation of detailed unit control: *In progress*
- Reference plant : Community power plant Hannover Stöcken
  - ▶ Dual block CHP plant (hard coal, 230 MW<sub>net</sub> / 425 MW<sub>th</sub>, process heat)
- Usage of dynamic simulation environment Dymola
  - ▶ Component library ClaRa



[2]




[3]



[4]



# Model of Water-Steam Cycle

- Current model (without detailed steam generator) contains all significant parts of WSC
- Detailed geometric parametrisation of components → Implementation of thermal inertia



# Own Model of Simple Subcooler

- Aim: Very simple modeling of heat transfer between shell / tubes
- Thermal inertia neglected
- For sub-cooling purposes only
- Characteristic line for part load heat transfer



KA2 in Stoecken\_24

General Summary and Visualisation Add modifiers Attributes

Component

Name KA2

Comment

Model

Path ClaRa.Components.HeatExchangers.Subcooler\_dyn

Comment

Icon

Fundamental Definitions

medium simCenter.fluid1 Medium in the component

PipesCold false True, if medium in tubes is cold

Heat Transfer

Q\_flow 484695 W Nominal heat transfer in the heat exchanger

m\_flow\_nom 3.927 kg/s Pipe mass flow in full load

PL\_heat [0.41, 0.34; 0.62, 0.57; 0.81, 0.79; 1, 1] Correction factor for heat transfer in part load

Pressure Losses

delta\_p\_tube 0 bar Pressure loss in tubes


delta\_p\_shell 0.416 bar Pressure loss in shell

OK Info Cancel



# Model of Steam Generator

- Current model (without WSC) contains all significant parts of a steam generator
- Detailed geometric parametrization of components → implementation of thermal inertia




Source: Project Thesis of O. Schirmbeck






# Preliminary Results WSC: Cond. Retention / Extension FWT

- Simulation of indirect cond. retention for short-term power increase to support primary control
- Water-side flow LP preheater reduced by throttling condensate pump
- Short-term power increase of 2.6%




# Preliminary Results WSC: Cond. Retention / Extension FWT

- Simulation of indirect cond. retention for short-term power increase to support primary control
- Water-side flow LP preheater reduced by throttling condensate pump
- Short-term power increase of 2.6%
- Example: Extension of feedwater tank (14.5 m → 29 m): Longer cond. retentions possible




# Upcoming tasks

- Merging of WSC- and steam generator model
- Implementation of detailed unit control
- Bugfixes in model
- Integration of cold condensate storage
- Integration of a model of the district heating network of Hannover



# Upcoming tasks

- Merging of WSC- and steam generator model
- Implementation of detailed unit control
- Bugfixes in model
- Integration of cold condensate storage
- Integration of a model of the district heating network of Hannover





We would like  
to thank:

**enercity**



# Thank you for your attention!





# References

[0]: [https://commons.wikimedia.org/wiki/File:Power\\_Plant\\_Stoecken\\_Hanover\\_Germany.jpg](https://commons.wikimedia.org/wiki/File:Power_Plant_Stoecken_Hanover_Germany.jpg)

[1]: Scharf: Vorlesung Kraftwerkstechnik II, 2019

[2]: [www.haz.de](http://www.haz.de)

[3]: [www.enercity.de](http://www.enercity.de)

[4]: [www.claralib.com](http://www.claralib.com)

[4]: [www.bildindustrie.de](http://www.bildindustrie.de)