



Use of ClaRa in the DYNSTART Project

A brief Overview

ClaRa User Meeting 2019

4 June 2019, Hamburg

IET
Institute of Energy Systems

Prof. Dr.-Ing. A. Kather

Jan Scheffler, M. Sc.

Jan Braune, M. Sc.

1. Background and Scope of DYNSTART
2. Modelling Approach and Model Structure
3. Expandable Connectors
4. Application of the Power Plant Model
5. Physically-motivated mill model
6. Summary

- **DYNCAP: Dynamic Investigation of thermal Power Plants**

- Predecessor to DYNSTART, duration 01/2011 to 09/2014
- Load range of 100 – 40 % (above Benson point)
- In cooperation with among others XRG and TLK (establish ClaRa library)

- **DYNSTART: Start-Up and dynamic Behavior of thermal Power Plants**

- Successor of DYNCAP, duration 08/2015 to 06/2019
- Extending load range from 40 % down to idle, including shut-down and start-up
- Additional focus on control system and step chains (ClaRa_Control)
- Evaluation of power plant operation in entire load range



- **Scenarios**


- Shut-down and different start-up procedures (cold, warm)
- Component surface heating, modified control of the high pressure bypass valve, etc.

- **Modelling in Modelica/ClaRa**

- Hard coal fired power plant according to a reference plant
- Including complete water-steam-cycle, air path, coal and oil supply, control systems and step chains
- Output 900 MW_{el,gross}, live steam 545 °C / 210 bar

- **Evaluation criteria**

- Thermal and mechanical wall stresses in crucial, thick walled components



- In total 120.000 equations, thereof 30.000 for control systems, 2.600 states

- **Modularized structure using replaceable models**

- Working in parallel in the same structure but with different focus
- Allows different levels of detail for each module
- Challenge of re-declaration, number of interface variables may differ

- **Expandable Connectors using BUS-System**

- Keeps model executable even if inputs are “missing”
- Beneficial especially for re-declaring controller modules
- Reduces number of (visible) connection drastically






Diagram View



Modelica Code View




- **Component wall stresses**

- ▶ For evaluation and comparison of different scenarios
- ▶ Pressure inside the components
- ▶ Temperature profile within the component walls
- ▶ Component geometry


Mechanical Stress

$$\sigma_m = \alpha_m \frac{d_{ms}}{2e_{ms}} \cdot p$$




Thermal Stress

$$\sigma_t = \alpha_t \frac{\beta_t \cdot E_t}{1-\nu} \Delta T_w$$




- **Component wall stresses**

- ▶ Fluid temperatures and pressures taken from ClaRa volume elements
- ▶ Application of heat transfer models in ClaRa wall elements
- ▶ Basis for stress calculation in component walls




- **Component wall stresses**

- ▶ Fluid temperatures and pressures taken from ClaRa volume elements
- ▶ Application of heat transfer models in ClaRa wall elements
- ▶ Basis for stress calculation in component walls
- ▶ MATLAB post-processing according to DIN 12952




• Oscillation Width of Wall Stresses

- ▶ Main evaluation criterion for simulation results
- ▶ Considering thick-walled component such as separator and high pressure outlet header
- ▶ Bar plot allows comparison of different scenarios
- ▶ E. g. start-up of cold/warm system, above mentioned component surface heating and modified high pressure bypass valve control




- **Building-up a mill model**

- ▶ ... based on physical equations
- ▶ ... for a wide range of application
- ▶ ... with interpretable parameters
- ▶ ... without a parametrization algorithm
- ▶ ... with reasonable computation time
- ▶ ... to model dynamic operation behavior



source: Steinmetz (1991)



Source: Niemczyk (2010)

• Roller-Bowl-Mills

- ▶ Raw coal supply via conveyor belt
- ▶ Grinding coal between bowl and rolls
- ▶ Transport and drying of the coal dust by hot primary air
- ▶ Classifying of the coal dust and separation in fine and coarse particles
- ▶ Each process takes place in a specific part of the mill


• Scenario

- ▶ Pre-qualification test to provide secondary control reserve
- ▶ Repeated load step of 90 MW_{el,net}

• Boundaries reference scenario

- ▶ **Grinding pressure** and **classifier speed** constant
- ▶ **Primary air mass flow** in dependence of **conveyor speed** without overdrive

$\Delta t = 466$ s to reach target value





• Boundaries scenario III

- ▶ Overdrive **grinding pressure** by max. 6 %
- ▶ **Primary air mass flow** and **classifier speed** controlled in dependence of conveyor speed, no overdrive

$\Delta t = 296$ s to reach target value

• Additional scenarios

- ▶ Scenario I: standard control
- ▶ Scenario II: overdrive primary air mass flow
- ▶ Scenario IV: double load gradient



- **Complete model of a hard coal fired power plant**


- Including control systems and step chains
- Modularized approach using expandable connectors
- Capable of covering the entire load range including shut-down and start-up
- Post-processing of stresses in thick-walled components, comparison of different scenarios

- **Physically-motivated mill model**

- Modelling sub-processes within a hard coal mill using physical equations
- Evaluating the potential of mill control for fast load changes
- Fully compatible with ClaRa-Library

- **Advanced control systems**

- Institute of Control Systems
- Multi-input-multi-output controller (MIMO)
- Model predictive control (MPC)
- Simulation data from Modelica
- Controller design in MATLAB/Simulink
- Co-Simulation using FMI



DYNSTART

Anfahren und transientes Verhalten von Kraftwerken



<http://www.tu-harburg.de/iet>

kather@tuhh.de

jan.braune@tuhh.de

jan.scheffler@tuhh.de

Supported by:



on the basis of a decision
by the German Bundestag

ID Number: 03ET7060D

Project Duration: 08/2015 to 06/2019



Back-Up